

MOBILE ATOMIC GRAVITY GRADIOMETER PROTOTYPE INSTRUMENT (MAGGPI)

Mark Kasevich

**Yale University
Department of Physics
New Haven, CT 06520**

September 2002

Final Report


APPROVED FOR PUBLIC RELEASE; DISTRIBUTION IS UNLIMITED.

20021129 053



**AIR FORCE RESEARCH LABORATORY
Space Vehicles Directorate
29 Randolph Road
AIR FORCE MATERIEL COMMAND
HANSCOM AIR FORCE BASE MA 01731-3010**

"This technical report has been reviewed and is approved for publication"



DAVID M. GLEASON
Contract Manager



GREGORY P. GINET
Branch Chief

This report has been reviewed by the ESC Public Affairs Office (PA) and is releasable to the National Technical Information Service (NTIS).

Qualified requestors may obtain additional copies from the Defense Technical Information Center (DTIC). All others should apply to the National Technical Information Service (NTIS).

If your address has changed, if you wish to be removed from the mailing list, or if the addressee is no longer employed by your organization, please notify AFRL/VSIM, 29 Randolph Road, Hanscom AFB MA 01731-3010. This will assist us in maintaining a current mailing list.

Do not return copies of this report unless contractual obligations or notices on a specific document require that it be returned.

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE 13 September 2002		3. REPORT TYPE AND DATES COVERED Final Report (Sept 2001-Sept 2002)
4. TITLE AND SUBTITLE Mobile Atomic Gravity Gradiometer Prototype Instrument (MAGGPI)			5. FUNDING NUMBERS PE: 69120G PR: N1MA TA: SD WU: A4 Contract #: F19628-01-C-0064	
6. AUTHOR(S) Mark Kasevich				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Yale University Department of Physics New Haven, CT 06520			8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Air Force Research Laboratory 29 Randolph Road Hanscom AFB MA 01731-3010 Contract Manager: David Gleason/VSBXT			10. SPONSORING/MONITORING AGENCY REPORT NUMBER AFRL-VS-TR-2002-1645	
11. SUPPLEMENTARY NOTES				
12a. DISTRIBUTION AVAILABILITY STATEMENT Approved for Public Release; Distribution Unlimited			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) During the one year of active development, Yale established subprograms to develop four key instrument systems. They were (1) field-ready laser systems (involving the design and construction of a ruggedized, portable laser system), (2) control electronics systems (developed the digital and analog electronics systems required to control each accelerometer sensor), (3) UHV vacuum system (developed prototype ultra-high vacuum systems based on all-glass sealing techniques and (4) platform motion simulation and control. For the latter, Yale evaluated the vibration environment in several candidate motion platforms. It also determined the specs for a suitable six-degree of freedom motion actuation system and developed a system concept and requirements for platform stabilization and control to achieve the required vibration environment for sensor operation. The detailed work related to each of these four instrument systems will not be present. The Principal Investigator accepted a position at Stanford University. A new contract will be started there and the effort will continue.				
14. SUBJECT TERMS Gravity gradiometry Atom interferometer Cold atom optics			15. NUMBER OF PAGES	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	20. LIMITATION OF ABSTRACT SAR	

Summary of Accomplishments During Active Period of Contract

During the one year of active development, Yale established sub-programs to develop 4 key instrument systems. They were (1) field-ready laser systems (involving the design and construction of a ruggedized, portable laser system), (2) control electronics systems (developed the digital and analog electronics systems required to control each accelerometer sensor), (3) UHV vacuum system (developed prototype ultra-high vacuum systems based on all-glass sealing techniques) and (4) Platform motion simulation and control. For the latter, Yale evaluated the vibration environment on several candidate motion platforms. It also determined the specs for a suitable six-degree of freedom motion actuation system and developed a system concept and requirements for platform stabilization and control to achieve the required vibration environment for sensor operation. The detailed work related to each of these 4 instrument systems will now be presented. *The Principal Investigator accepted a position at Stanford University and a new contract will be started there and the effort will continue.*

Field-ready laser systems: A slave laser module was developed. It contains eight high-power semiconductor lasers for use in a master-slave configuration. For each slave laser, light from a master is brought into the system through a single-mode polarization preserving optical fiber, after which it is fed into the facet of an SDL laser running at 852 nm. In this configuration, the output light from the slave is frequency matched to the frequency of the input beam, with an additional frequency offset provided by a double-passed acousto-optic modulator (AOM). The AOM is also used to control the intensity of the output laser field. In the design and construction of this frame, Yale evaluated slave lasers from competing suppliers before selecting the SDL model. In order to improve injection locking reliability, Yale had the laser facets anti-reflection coated and applied a beam circularizing micro-lens to the laser output. The final lens shapes the mode into a circular Gaussian and enables high efficiency coupling into an optical fiber. An independent electronics subsystem provides the required high stability current and temperature regulation to the lasers.

Control electronics system: Electronics development focused on two sub-systems: the high stability temperature and current controllers required to drive the semi-conductor lasers and the digital/mixed signal electronics required to control the overall function of the sensors. A laser current and temperature controller were used to drive the semi-conductor lasers. Yale evaluated commercial and in-house controller designs before settling on an in-house design that showed substantially improved current noise performance. Commercially off the shelf temperature controllers from Wavelength Electronics were adequate for the overall design.

For the digital/mixed signal control electronics, Yale evaluated hard real-time control solutions based on PC104/Intel CPU and TI DSP architectures, before selecting the TI DSP solution. Initial performance tests indicated much greater hardware/software stability and lower timing jitter for the DSP based system. Innovative Integration was identified as the prime vendor for DSP cards due to the availability of high channel

density (16 analog), intermediate speed (100 Ks/sec) daughter cards. The system core is built around a single C6711 SBC card. Code is written in C and the interface to the DSP is via TI's Code Composer Studio v.2. Agile RF control is accomplished using digital output from the C6711 to control compact Novatech DDS cards. It was verified that Novatech DDS has adequate phase-noise characteristics for the contract's relatively demanding application. In-house digital interface cards are used to coordinate control signals between the DDS and controlling DSP host.

Vacuum systems: Yale developed in-house all glass sealing techniques. These techniques were also used to demonstrate exceptional mechanical stability – performing significantly better than optical contact seals. Specialized techniques were developed yielding ultra high vacuum compatible seals for Zerodur and Quartz. Two prototype chambers were developed using this technique during the first performance year.

Platform simulation and control: Yale initiated a program to identify promising platform actuation techniques, and to acquire information on the vibration environment of candidate platforms. Its platform actuation analysis had two focuses: to accurately simulate the vibrational environment of candidate vehicle platforms and to develop a strategy for controlling the orientation of the actual survey system. As these two work areas are tightly linked, groundwork was laid for detailed design work for both.

Field platform vibration/rotation data was acquired for three candidate platforms: UH1 Helicopter, Bell 206 Helicopter, and a Chevrolet Suburban. Data were acquired with a pair of Crossbow IMU's to ensure measurement integrity and several high bandwidth Crossbow accelerometers. A detailed analysis of all vibration records was performed providing key inputs into the design and specification of the six degree of freedom motion base needed for this contract.

A survey of available commercial motion-base solutions was performed as well as an evaluation of platform performance with respect to what was identified as the key performance requirements: Position, velocity, acceleration dynamic range and motion actuation bandwidth. The relatively large amplitude acceleration noise at high frequency induced by the rotor motion presents a stringent constraint which rules out many commonly used actuator types. A performance study was commissioned to specifically evaluate these high frequency performance characteristics. The study, carried out by Parallel Robotics, a manufacturer of hexapod based machining systems, indicated that achieving large amplitude low frequency motion plus high frequency rotor motion would be difficult to achieve with commonly used actuators. As a result, the Yale team has sought to identify breakthrough actuator technologies that will enable faithful simulation of a broad range of motion environments. The team identified a servo-ram linear motion actuator that is likely capable of meeting these requirements.

In addition to a full simulation of platform motion, the effort also requires a motion-base to simulate the less demanding motion environment present at the sensor itself. The characteristics of this environment will be determined by the 6 degree of freedom vibration isolation system (to be designed and tested in the 3rd and 4th year of the effort at

Stanford U.) and are benign in comparison to the raw motion environments of the host vehicle. Yale identified a commercial supplier for this platform. The MaxCue motion system the team ordered will enable the first sensor performance studies in mid FY03 at Stanford U.